



The manufacturer may use the mark:



Revision 2.0 April 29, 2022  
Surveillance Audit Due  
May 1, 2025



# Certificate / Certificat Zertifikat / 合格証

STR 1011040 C001

*exida* hereby confirms that the:

## Metal Seated & Soft Seated Piston Valves

**Strahman Valve, Inc.  
Bethlehem, PA - USA**

Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-2**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

### Safety Function:

The Metal Seated and Soft Seated Piston Valves will move to the designed safe position per the actuator design within the specified safety time.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

# Certificate / Certificat / Zertifikat / 合格証

STR 1011040 C001

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

### Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

### Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2<sub>H</sub>.

### Versions:

Application	Valve Series	Sizes	Pressure Rating
Soft Seated (SV)	SV Series	3/8" through 14"	CL 150 - 600 PN 10 to PN 630
Metal Seated (MS)	M Seal, Rising Stem	3/8" through 14" PN 10 to PN 630	CL 600 - 1500 PN 10 to PN 630
	M Ring Seal, Rising Stem		
	Dual Seal, Rising Stem		
	M Seal, Telescopic Stem		
	M Ring Seal, Telescopic Stem		
	Dual Seal, Telescopic Stem		

### IEC 61508 Failure Rates in FIT<sup>1</sup>

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
Full Stroke, Clean Service	0	0	0	476
Tight Shut Off, Clean Service	0	0	0	1077
Open on Trip, Clean Service	0	137	0	339
Full Stroke, Severe Service	0	0	0	833
Tight Shut Off, Severe Service	0	0	0	2036
Open on Trip, Severe Service	0	272	0	561

<sup>1</sup> FIT = 1 failure / 10<sup>9</sup> hours

### SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** STR 10/11-040 R003 V4 R1 (or later)

**Safety Manual:** : QMS 12.001 SVI Safety Manual (or later)

Metal Seated & Soft  
Seated Piston Valves



80 N Main St  
Sellersville, PA 18960

T-062, V5R2